

# **2021 Annual Drinking Water Quality Report**

## **Town of Chocowinity**

PWS ID# "04-07-025"

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about from where your water comes, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact the Town of Chocowinity at (252) 946-6568. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at the Town of Chocowinity Municipal Building the 1<sup>st</sup> Tuesday of every month at 7:00 pm.**

### **What EPA Wants You to Know**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

### **When You Turn Your Tap on, Consider the Source**

The water that is used by this system is ground water that comes from four wells. Well #2A is located at the Edgewood Drive Water Plant, Well #3 is located at Chocowinity Recreation Complex, Well #5 is located on Albritton Drive off of Old Blounts Creek Road, Well #4 is located at the Hill Road Water Plant.

## Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower. The relative susceptibility rating of each source for the Town of Chocowinity was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating	SWAP Report Date
Well # 2A	Moderate	2020
Well # 3	Lower	2020
Well # 4	Lower	2020
Well #5	Lower	2020

The complete SWAP Assessment report for Town of Chocowinity may be viewed on the Web at: [https://www.ncwater.org/SWAP\\_Reports/NC0407025\\_SWAP\\_Report-20200909.pdf](https://www.ncwater.org/SWAP_Reports/NC0407025_SWAP_Report-20200909.pdf). Please note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to [swap@ncdenr.gov](mailto:swap@ncdenr.gov). Please indicate your system name, PWSID, and provide your name, mailing address and phone number. If you have any questions about the SWAP report please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the systems’ potential to become contaminated by PCS’s in the assessment area.

## Water Quality Data Table of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1-December 31, 2021. The EPA of the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

### Important Drinking Water Definitions:

*Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Action Level* - the concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Extra Note:** MCL’s are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

### Microbiological Contaminants

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	N	0	0	one positive monthly sample	Naturally present in the environment
Fecal Coliform or E. coli (presence or absence)	N	0	0	0 (Note: The MCL is exceeded if a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive)	Human and animal fecal waste

### Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Fluoride (ppm)	2019	N	1.1	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Manganese (ppm)	2019	N	0	N/A	.050	.050	Erosion of natural deposits

### Volatile Organic Chemical (VOC) Contaminants

Contaminant (Units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Xylenes (Total) (ppm)	2021	N	.0006	N/A	10	10	Discharge from petroleum factories; discharge from chemical factories
Ethylbenzene (ppm)	2021	N	0	N/A	.700	.700	Discharge from petroleum factories; discharge from chemical factories

### Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90 <sup>th</sup> percentile)	2021	.142	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb) (90 <sup>th</sup> percentile)	2021	0	0	15	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

*Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).*

### Disinfectants and Disinfection Byproducts Contaminants

Contaminant (units)	Sample Date	MCL/MRDL Violation Y/N	Your Water (AVG)	Range Low High	MCLG	MCL	Likely Source of Contamination
TTHM (ppb) [Total Trihalomethanes]	2021	N	25.25	L = 22.9 H = 27.6	N/A	80	By-product of drinking water chlorination
HAA5 (ppb) [Total Haloacetic Acids]	2021	N	7.8	L = 6.1 H = 9.5	N/A	60	By-product of drinking water disinfection
Chlorine (ppm)	2021	N	1.31	L = .42 H = 2.2	MRDLG = 4	MRDL = 4	Water additive used to control microbes

*Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.*

Secondary Contaminants, required by the NC Public Water Supply Section, are substances that affect the taste, odor, and/or color of drinking water. These aesthetic contaminants normally do not have any health effects and normally do not affect the safety of your water.

### Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water Average	Range Low High	Secondary MCL
Sodium (ppm)	2019	51.58 mg/L	L = 51.32 H = 51.83	N/A
pH	2019	7.5 units	N/A	6.5 to 8.5

### What if I have any questions or would like to become more involved?

If you have any questions about this report or concerning your water utility, please contact Kevin Brickhouse (Town of Chocowinity- Public Works Director) at 252-946-6568 Monday - Friday 8:00am - 5:00 pm.